

# **Strong Acid Cation Exchange Resin**

# $001 \times 7.5$

 $001\times7.5$  is a polystyrene matrix of gel type strong acid cation exchange resin containing sulfuric acid, which is equivalent to solid sulfuric acid. Mainly used for water treatment industry.

#### **Index**

Name	Specification
Appearance	Pale yellow clear spherical beads
Polymer	Styrene-DVB-Copolymer,gel-type
Functional Group	-SO₃H
Ionic Form	Na <sup>+</sup>
Weight Exchange Capacity	≥4.5mmol/g
Volume Exchange Capacity	≥1.9mmol/ml
Real Density (g/ml)	1.25~1.29g/ml
Bulk Density (g/ml)	0.77~0.87g/ml
Water Retention Capacity	45%~50%
Particle Size Range	0.315~1.25 mm≥95
Uniformity Coefficient	≤1.6
Whole Bead Count (%)	≥95%

### **Reference Operation Conditions**

Maximum operating temperature	120℃
Resin filling height	1~3m
Operating velocity	2~10BV/h
Backwash velocity	4~10BV/h
Regeneration (desorption) velocity	1~2BV/h
Regeneration agent	2BV3~5%HCI,2BV2~4% NaOH



## **Application**

- Water softening
- Preparation of pure water
- Wet metallurgy
- Rare element separation

#### **Precautions**

- Resin should be wet state preservation. The best temperature is above 0°C. Resin should be put into a closed space or add in salt water of 5% or above if not used for a long time. Should be anti-freezing during transportation. Do not place heavy objects on the resin in case being crashed
- Generally requires alkali- water acid water flow path for processing. Strict requirement needs three circulation before coming to final ion kenel.
- Need to consider different transformation expansion rate to set aside enough space to
  prevent resin overflow and ensure the appropriate liquid level height; Column diameter
  ratio should be within a reasonable range and avoid bias current; Use wet packed column or
  back-flushing to wash away bubbles inside resin layer.
- Before liquid going into the resin column, steps as flocculation, filtration, or sand-filtration should be taken so that it doesn't jam resin pore with suspended solids.
- Resin inside the column that hasn't been used for a long time should be storaged outside of
  the column after washing, or adding salt water in the salt resistant medium while keeping
  liquid level not dehydrated with usual backwashing to loosen resin in case of
  agglomeration.